

Cells Series	Banks Parallel	Voltage (Upper)	Voltage (Low)	Nominal Capacitance (F)	Ab Max Voltage (V)	Ab Min Voltage (V)	Pulse ESR (10ms)	~ESR (IEC)	IEC 1s Rating	IEC 2s Rating	IEC 5s Rating	CCA (3 Sec Max Method)	Maximum Power (kW)	Current Leakage (mA)	Energy within Op Window (kJ)	Energy At Max V (kJ)
5	1	14.5	7	630	15	0	0.00094	0.0016	2310	1530	760	1180	56.22	4.5	50.8	70.9
6	1	14.5	7	525	18	0	0.00112	0.0019	1920	1270	630	990	46.85	4.5	42.3	85.1
5	2	14.5	7	1260	15	0	0.00047	0.0008	4620	3060	1520	2370	112.4	9	101.6	141.8
5	4	14.5	7	2520	15	0	0.00023	0.0004	9240	6130	3050	4750	224.9	18	203.2	283.5
10	1	29	8	315	30	0	0.00187	0.0031	2310	1530	760	1660	112.4	4.5	122.4	141.8
12	1	29	8	263	36	0	0.00224	0.0037	1920	1270	630	1380	93.69	4.5	102.0	170.1